

The City of Manassas Electric Company filed that no interference was occurring from the BPL installations that were operational. This is totally incorrect. The OVH members' BPL task force has recordings and documented interference from two separate locations that were 40 db over S9 and completely overriding all signals on 7255(40 meters).

The Electric Company has accompanied the task force and observed themselves the high levels of interference. This is especially true on the overhead lines on the Signal Hill site and Traveller and Weir Streets. Other reports have been filed with the FCC and we have worked closely with the Manassas City officials, so we don't understand the Electric Company stating that there has been no reports of interference.